

I.C.R. W.U.A. Monthly Operator Notes
July 22, 2014

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked to ensure no leaks or issues with our line

Concrete landing will be completed this month

Molly Way fire pumps were taken apart and cleaned,
They are operating normally

Enviro Tech Electrical has installed all equipment per their bid and is waiting on some programming information for the Molly Way Flo-Tronic unit.

Battery back-up is in place at Cooper Morgan boost station

Meter verification program for 2014 should be completed this week (55)

Checked the fire hydrants on the fire dept. list and all are functioning fine, we dug the hydrant on Centennial for easier access

Harvey has received bids for painting of the WC and Cooper Morgan tanks

Weed abatement is ongoing

Meter reads went well in June

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time.

