

I.C.R. W.U.A. Monthly Operator Notes  
November 25, 2014

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked to ensure no leaks or issues with our line

Installed new meter on ICR well #1 discharge line

Still waiting on the bearing replacement quote for the Cooper Morgan boost station

We ordered and installed new check valve for the high pressure skid at Molly Way also discovered that the pressure sensor was bad, it has been ordered and should be installed this week

Enviro-Tech has had no success with Flo-Tronics in getting the codes they need

Tentative date for the tank cleaning was November 3 it was canceled and rescheduled for after the first of the year, we have heard nothing from the tank painter

A door hanger was left on a residence on Inscription Canyon Dr. per Cheryl's request

Meter reads went well this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the above mentioned.

