

I.C.R. W.U.A. Monthly Operator Notes
August 26, 2014

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked to ensure no leaks or issues with our line

Concrete landing have been completed

Meter verification program for 2014 has been completed

Enviro Tech is waiting on the programmer to look at Molly Way, looks like we may need a new program installed in the PLC

ICR wells sounded per Bill's request

Valve exercise program to begin in Sept.

4 new meter installs this month all in TRR

Weed abatement is ongoing

Meter reads went well in July

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time.

