

I.C.R. W.U.A. Monthly Operator Notes
October 28, 2014

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked to ensure no leaks or issues with our line

The valve exercise program is complete for 2014

Hydrant, ARV inspections are complete, (1) ARV was found to be leaking we have ordered parts and will repair it when they arrive

The #1 boost pump at the Cooper Morgan boost station has started to leak, the bearing needs replaced. Enviro Tech is getting a proposal for the work, (still waiting for the proposal)

ICR well #2 off-line ICR well #1 is primary, repairs were made while it was off-line (New saddle, New chlorine injector and new chlorine line.)

We ordered a silent check valve for the high pressure skid at Molly Way

Tentative date for tank cleaning is November 3rd

Weed abatement is coming to an end for the year

Meter reads were a little weird this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the above mentioned.

