

I.C.R. W.U.A. Monthly Operator Notes  
September 22, 2014

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked to ensure no leaks or issues with our line

The level transducer at the Cooper Morgan tank failed over Labor Day weekend. The flow to the golf course was stopped until the transducer was replaced on the 3<sup>rd</sup>. We now have a backup transducer on hand

Enviro Techs programmer attempted to get into the Molly Way flotronics program and after several hours of trying to get in was unsuccessful we may need to hire the flotronic rep. to look at the unit,

The #1 boost pump at the Cooper Morgan boost station has started to leak, the bearing needs replaced. Enviro Tech is getting a proposal for the work

I am getting some quotes for radio read meters and equipment from HD and Dana Kepner for the Board to consider

We have the proposals for the fence work at Molly Way and the tank cleaning

Weed abatement is ongoing

Meter reads were a little weird this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the above mentioned.

