

I.C.R. W.U.A. Monthly Notes  
May 2014

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked to ensure no leaks or issues with our line

We would like to pour concrete pads in front of the Copper Morgan, Double Adobe front doors and the Grey Bears back door. We have left over cement. Mixer rental and 5-10hrs labor we can get it done/ discussed last month not sure we had an answer yet

New Mission air card upgrade was completed at the Cooper Morgan boost station, all tank levels were reset back to normal.

Enviro Tech Electrical solutions has ordered the equipment per the bid approval and will install the surge protection and alarm dialer at the ICR well field when all equipment is received

2 new meters were installed at house construction sites (TRR)

Meter verification program for 2014 will begin next month

Weed abatement is ongoing

Meter reads went well in May

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time.

