

I.C.R.W.U.A. Monthly Operator Notes  
February 28, 2017

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line. 24 fiberglass line indicators were ordered, received and will be installed in the next few weeks.

Derek discussed and showed Bill the issue with the fences on our right of way road. They will attempt to contact property owners for access

The new spool that was ordered for the Molly Way boost station should be here this month.

Contacted MCI to arrange for a technician to assess the Molly Way PLC issues.

Block heaters were replaced on the Molly Way generator

I would like to contact Gen-Tech for pricing on generator servicing, with Board approval

Investigated a customer complaint for cloudy water on Indian Camp

Two meter installs this month (1) TRR and (1) WC

Meter reads went well this month. Five re-reads, all were correct

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the Molly Way program issue