

I.C.R. W.U.A. Monthly Operator Notes
August 23, 2016

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line

The needle valve on the deep well control valve on ICR #1 was sent to the factory for repairs we expect this to be complete this month

Generator at Molly Way boost station battery was bad (one of the new batteries) it has been replaced and is up and running

2 emergency call outs this month due to lightning (Cooper Morgan boost station)

Ordered the 1 ½ meters to complete the commercial/landscape meter task

1 meter install (TRR)

Weed abatement is on-going

Meter reads went well this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the Molly Way program issue

