

I.C.R. W.U.A. Monthly Operator Notes
January 27, 2015

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked to ensure no leaks or issues with our line

Molly way CL2 injection system is installed and operational

The seals are scheduled to be replaced the first week of Feb. at Cooper Morgan boost station

No word on the painters or divers for the WC tank

We ordered and installed another new check valve for the high pressure skid at Molly Way

We have a call into Rod Baker from Flow-Tronics waiting for him to respond

Received a complaint from a residence on Grey Bear about air in his water, we checked and cleaned the nearest ARV and flushed the lines

Repaired a large leak in TRR on Longview Dr.

6 new meters were installed in Dec.

Meter reads went well this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the above mentioned.

