

I.C.R. W.U.A. Monthly Operator Notes
July 26, 2016

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line

Survey pins and monuments at the Whispering Canyon tank are complete

Completed 60 meter verification checks (yearly) per BMP's

The needle valve on the deep well control valve on ICR #1 was sent to the factory for repairs

We will be installing micro-filters on both ICR wells due to sand fouling the needle valves on the deep well control valves

Completed the Stage 2 DBP monitoring plan for both systems and received approval from ADEQ

Heatherbrae Dr. was flushed due to odor complaint

2 meter installs (TRR)

Weed abatement is on-going

Meter reads went well this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the Molly Way program issue

