

I.C.R. W.U.A. Monthly Operator Notes  
June 28, 2016

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line  
4 of the 6 (2in.) landscape/commercial meters have been rebuilt and reinstalled we also  
completed 9 verifications on the meters that were on the list

We had issues with the Whispering Canyon boost station, floats were bad and replaced

After further investigation of the leak on Haidee Circle, it was discovered that a meter  
setter on a vacant lot was leaking, the leak never surfaced. Derek and Casey made the  
repair and Steve Norris was called off

All 2015 CCR forms were completed and sent to ADEQ

The annual ACC report was completed and submitted

Meter reads went well this month

Monthly and annual samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the Molly Way  
program issue

