

I.C.R. W.U.A. Monthly Operator Notes
November 24, 2015

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked 2 times this month to ensure no leaks or issues with our
line

Valve exercise program is complete for 2015

Talked to the Fire Dept. about contacting us in advance of their activities in the service
area

Checked all generators for fuel and coolant levels going into winter

Derek and Harvey located all non-residential meters

Heaters were turned on and checked for operation in all buildings

Replaced chlorine injection unit at TRR well #1

Meter reads went well this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the Molly Way
program issue

