

I.C.R. W.U.A. Monthly Operator Notes
October 27, 2015

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked 2 times this month to ensure no leaks or issues with our
line

Valve exercise program will be completed by Nov. 1

Hydrant leak detection is completed 4 hydrants were leaking and fixed

1 meter verification was done on Yaqui, per customer request, meter was 2% out

Talked to fire Dept. about taking over hydrant service, haven't heard back from them

Weed abatement is coming to an end for the year

Emergency call out to Copper Morgan boost station on 10/17

Meter reads went well this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the Molly Way
program issue

