

I.C.R. W.U.A. Monthly Operator Notes
July 25, 2017

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line.

Enviro-Tech has started work on the pressure tank and alarm dialers at Molly Way, work should be completed by the end of July.

Discharge meter on ICR well #1 is not functioning correctly until we identify and repair the problem, we have been estimating the discharge

Installed 20 line markers for the TRR transmission line

Meter verification program has started 15 have been completed in ICR

(4) Meter installs this month (3) TRR (1) ICR

Weed abatement is ongoing

Meter reads went well this month.

Monthly and Annual samples were collected and delivered to the lab.

All equipment is working properly at this time with the exception of the Molly Way program issue