

I.C.R. W.U.A. Monthly Operator Notes  
June 24, 2014

The easement road was checked to ensure no leaks or issues with our line.

Enviro Tech Electrical solutions has completed the power/lighting surge protection at all boost stations and installed the Mission dialer at the ICR wells.

2 emergency call outs this month (1) at the ICR well field power supply circuit to the cla-valve failed (2) Real estate person called in a water leak on Thunderbird, nothing found.

Pump and motor information is available in all boost stations.

New blind flanges were installed at the Grey Bears pump house

We are having issues with the generator at the Cooper Morgan boost station. I have been in contact with the company to resolve this.

During a flushing and pump exercise at Molly Way boost station both fire pumps faulted. John Patton was there working on the surge protection project, he thinks there is something stuck in the pumps. Derek and John will be taking the pumps apart Tues 6/24 to see what the problem may be.

10 dead end hydrants were flushed in ICR (30k) water and 21 in TRR (50k) water

Weed abatement is ongoing

Meter reads went well in May

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the equipment mentioned above.