

I.C.R. W.U.A. Monthly Operator Notes
June 23, 2015

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked 2 times this month to ensure no leaks or issues with our
line

Magner boost station meter sent back to McCrometer to be calibrated, should be back
next month

Well meter are due to be checked 3 years are up in Dec. / Jan.

21 high usage meters were verified, 11 were out more than 3%

We're still having trouble with the Flo-tronics rep. Jimmy, Derek and I will be talking
before the meeting to discuss

Emailed Empire to schedule generator service. We also will call for fuel refill

We will be flushing dead end lines this month

Weed abatement is ongoing

3 new meter installs in TRR this month

Meter reads went well this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the above
mentioned.