

I.C.R. W.U.A. Monthly Operator Notes
May 29, 2017

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line.

Enviro-Tech has ordered the mission dialer and will be giving a quote to bring the air/water tank online and the new programming for the control panel

Gen-tech rep. was onsite to look at the generator units and will give a timeline for service

Fire Dept. is doing their hydrant inspections in both TRR and ICR

Ordered 20 more line markers for the TRR transmission line, we will install them when we receive the order

4 new meters installed (TRR)

Weed abatement is ongoing

Meter reads went well this month.

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the Molly Way program issue