

I.C.R. W.U.A. Monthly Operator Notes
January 2018

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line.

The generator radiator at the Molly Way boost station failed on New Year day... (Happy New Year) the parts are on order and it will be repaired ASAP

The 75hp and the 40hp motors were replaced at the Cooper Morgan boost station by Enviro-Tech it appears that the pump impellers are starting to wear, the pump are only at 20% efficiency

Molly Way program is being written and will be installed the first week of February

Since the hydro tank was put on-line at Molly Way the cycles on the booster pumps are down from ~2500 to ~300 per month this should show on the APS bill

(2) new meter installs in TRR and (1) bad meter replacement

Meter reads went well this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the Molly Way program issue