

I.C.R. W.U.A. Monthly Operator Notes
February 16, 2018

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line.

The radiator on the Molly Way boost station generator has been replaced, serviced and load tested, Cooper Morgan generator has been serviced and load tested as well

The rebuilt 75hp and the 40hp motors for Cooper Morgan boost station will be delivered on the 21st

Molly Way programing is complete and seems to be working correctly for the first time ever. Thanks for letting us finally get this completed!!! There were 22hrs. Of fine tuning and flow testing, now we can collect some real data from this boost station.

No Trespassing signs are on all facility fences and ARV's will be painted and reflective tape installed as soon as it dries out and warms up

We have 2 roofers and 2 painters lined up to visit the sites and give proposals early next week

Three new meter installs (2) TRR (1) ICR

Received another quote for radio read meters

Meter reads went well this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time EVEN the Molly Way program issue

