

I.C.R. W.U.A. Monthly Operator Notes
May 2018

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our lines. We found a leaking ARV on the ICR transmission line and replaced it

Roofing and Painting work has been completed

All new radio reads meters that were purchased are in the ground (98) we have 4 of each size in stock for new installations

Met with the meters representatives from Fortiline and went over the computer that will read the meters and also met with Cheryl and went over that end of the process

(3) new meter were installed, (1) TRR (2) ICR

Weed abatement has started for the season

Meter reads went well this month, (9) re-reads, 1 was incorrect

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

