

I.C.R. W.U.A. Monthly Operator Notes  
September 2018

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our lines.

All new radio read meters are installed with the exception of the well meters, they have been ordered

The read computer and the billing software are all in sync. and the training went good.  
We will do the first read on the 15<sup>th</sup> of Oct.

Well houses and pump stations are ready for winter months

Well call orders will be changed at TRR well field for slow season

Both generators were serviced and batteries were changed at Molly Way generator

Valve exercised program has begun for the year, per BMP's

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

