

I.C.R. W.U.A. Monthly Operator Notes
June 2019

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our lines

Met with the Hydrologist to do a tour of the well fields

All well meters have been installed

New insertion valve and repair were completed at the ICR well #1

(6) New meters were installed (4) TRR (2) ICR

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

