

I.C.R. W.U.A. Monthly Operator Notes
July 2019

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our lines

Hydrologist preformed a draw down test on ICR well #1

A leak was found and repaired on the ICR transmission line approximately 7 gpm

The well control valves were rebuilt on the ICR wells

(5) New meters were installed (4) TRR (1) ICR

(2) Hydrant meters were installed at the fire station

Forest service is using water for firefighting uses

Weed abatement is on-going

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

