

I.C.R. Water Co. Monthly Operator Notes
December 2020

General maintenance and operations is ongoing

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our lines

More flushing was completed at Sterling Ranch

Emergency call out on Thunderbird

Programing at Cooper Morgan boost station is almost completed, Hydro tank is back online, waiting for the program for the Jockey pump

(3) new meter installs (1) ICR (2) TRR

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the programing mentioned above

