

I.C.R. Water Co. Monthly Operator Notes  
January 2021

General maintenance and operations are ongoing

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our lines

Molly Way generator had a coolant leak, Empire was called and issue was fixed

Called for a service leak on Three Forks, leak was on our side of the meter and repaired

(7) new meter installs (6) ICR (1) TRR

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

