

I.C.R. W.U.A. Monthly Operator Notes
February 24, 2015

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked to ensure no leaks or issues with our line

Still waiting on the seals for the Cooper Morgan boost pumps

Painters completed the WC tank on 2/5/15 and did a nice job, divers are supposed to contact us in March to set a time for cleaning and inspection

Took a survey of valve cans and found 10 that need attention

We received a call from Rod Baker from Flow-Tronics he is investigating the issue and will be in contact with us on what he found

Enviro Tech Replaced the H.O.A. (hand/off/auto) switches at the Cooper Morgan boost station we had an issue with one so we replace all of them.

We were contacted by the Yavapai Fire District to demonstrate the correct way to open and close the hydrants on the water system, we will be doing this on 2/25

We have a main line leak on OK Drive in TRR, Steve Norris is scheduled to repair this week..

Meter reads went well this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the above mentioned.

