

I.C.R. W.U.A. Monthly Operator Notes
July 28, 2015

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked 2 times this month to ensure no leaks or issues with our
line

Magner boost station meter was sent back to McCrometer recalibrated, and reinstalled

We have not yet finished the last 8 high use meter verifications, we will attempt to have
them complete before the next meeting

We are still having issues at the Molly Way boost station

Generators were serviced and refueled this month

We flushed several dead end lines this month, and will continue flushing next month

Weed abatement is ongoing

Meter reads went well this month, found a customer side leak on Indian Pony left a door
hanger and notified Cheryl

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the above
mentioned.

