

I.C.R. W.U.A. Monthly Operator Notes  
March 22, 2016

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line

Dana Kepner the factory rep. for the lake meter checked the accuracy of the meter with a special verification toll for bigger meters, it was found to be working correctly

Well meter program is ongoing, TRR well #3 was returned and meters for ICR #1 and TRR #1 were sent out

The 5 high use meters the Board wanted replaced is complete (all ICR)

5 new meter installs all in TRR

The Molly Way generator had an alarm (High Fuel Level) the generators were serviced yesterday 3/21 and the tech. will check the alarm.

The Copper Morgan and Molly Way generators had annual services completed on 3/21

The 2" Neptune was rebuilt

Meter reads went well this month, Derek is happy with the new tablet

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the Molly Way program issue

