

I.C.R. W.U.A. Monthly Operator Notes
March 24, 2015

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked to ensure no leaks or issues with our line

Still waiting on the seals for the Cooper Morgan boost pumps

We were contacted by the tank diving company, tentative schedule for the first week in
April

Valve can repairs will take approximately 100hrs of labor, 3-4 bags of concrete each,
valve can risers (\$25 ea.) from HD supply and permits from the county.

Contacted by Mr. Friend and a programmer from the Flow-Tronics office in Texas They
determined that a complete system re-boot should be done and Rod Baker needed to be
on-site to do this, waiting for a date.

We demonstrated to Yavapai Fire District the correct way to open and close the hydrants
on the water system, and explained what happens to our equipment when it is not done
correctly, a training video was also done at the time.

The main line leak repair on OK Drive in TRR, was completed by Steve Norris. The
gasket in the bell was not seated correctly

Meter reads went well this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the above
mentioned.

