

I.C.R. W.U.A. Monthly Operator Notes  
May 26, 2015

Molly Way was flushed twice and the fire pumps exercised. VFD fault on pump #3 appears to be working correctly.... Another strangeness with the unit.

The easement road was checked to ensure no leaks or issues with our line

Valve can project was put on hold to look into water loss on ICR side.

Checked well meters and boost station meters found the Magner boost station meter off by 6% we are sending back for calibration.

Well meter are due to be checked 3 years are up

Found 4 meters not reading flow all were replaced and have the list of high usage meters to be verified, starting 5/26

We're still having trouble with the Flo-tronics rep. Jimmy has helped facilitate a conference call

Generators are due for service.

Meter reads went well this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the above mentioned.

