

I.C.R.W.U.A. Monthly Operator Notes  
March 28, 2017

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line.  
Fiberglass line indicators were installed on the easement

The new spool that was shipped from Hennesy for the Molly Way boost station it will be installed as soon as it arrives

Waiting for a date from MCI technician to assess the Molly Way PLC issues.

I received 2 proposals for generator service, will provide copies at the meeting

Investigated (2) customer complaints for air in water (Grey Bears and Almosta Ranch) lines were flushed

Switched from ICR well #2 to well #1 at the first of the month

Maintenance on chlorine injection systems at well sites was complete

Seven new meter installs this month (2) Preserve (1) ICR (4) TRR also replaced (1) faulty meter in TRR

Located new service on Turning Mountain with the help of Norco, it may be a good idea to locate all unidentified services and install meter boxes on the properties

Meter reads went well this month.

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the Molly Way program issue