

I.C.R. W.U.A. Monthly Operator Notes  
November 22, 2016

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line  
We did find a well driller next to our line Derek talked to him and mentioned he should  
have had the line blue staked

Completed the installation of the targeted commercial meters

Discovered coolant leak on the Molly Way generator, service tech was called and repair  
should be complete next week

We found a leak on the discharge pipe on pump 1 in the Molly Way boost station, we  
have calls in for the equipment rep. so we can order the replacement pipe

1 meters installed (TRR)

Yearly Hydrant leak detection is complete, found 2 that were not completely closed

Fire Dept. was out to flush hydrants (45)

Yearly valve exercise program is ongoing

Meter reads went well this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the Molly Way  
program issue