

I.C.R. W.U.A. Monthly Operator Notes  
April 2017

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line.

The new spool for the Molly Way boost station has been installed

Enviro-Tech will be here on the 28<sup>th</sup> to look at the Molly Way issues

Gen-tech has been in touch with us and will be servicing the generators soon

Fire Dept. tested fire flows in the new TRR phases on 4/24/17

(2) New meter installs this month (1) TRR and (1) in ICR

(2) Bad meters were identified and replaced (1) TRR and (1) W.C.

Survey of empty lot meter locations has started

Weed abatement has started for the season

CCR and ADWR reports are complete

Meter reads went well this month.

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the Molly Way  
program issue