

I.C.R. W.U.A. Monthly Operator Notes
April 2018

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line.

Roofing work is complete and painting is scheduled to be completed in May

New high pressure chlorine pump has been installed on ICR well #1

MAP testing by ADEQ was completed this month

(3) new meter were installed, (2) TRR (1) ICR

Half of the new radio read meters have been installed, all 100 will be in the ground by the end of the month

Meter reads went well this month, (6) re-reads, all were correct

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

