

I.C.R. W.U.A. Monthly Operator Notes
March 2018

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line.

The new Molly Way program is working the way we intended

All paint and roofing proposals are in, the roofing work should be starting soon.

New high pressure chlorine pump has been ordered for ICR well #1 and will be installed as soon as it is received.

ARV's are painted

One new meter installed, TRR

Six bad meters were discovered during reads, all were replaced and one was sent back for warranty credit

Meter reads went well this month, (7) re-reads, all were correct

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

