

I.C.R. W.U.A. Monthly Operator Notes  
July 2018

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our lines.

New radio reads meters that were purchased are in the ground (295) we have 4 of each size in stock for new installations, we are trying to have all of the ICR side of the road completed by Aug. 1

We purchased another new hydrant meter the old one was not metering correctly.

Weed abatement is on-going

New roofs and paint seem to be holding up fine

Meter reads went well this month, (10) re-reads, 2 incorrect

Monthly and some yearly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

