

I.C.R. W.U.A. Monthly Operator Notes
August 2018

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our lines.

New radio reads meters that were purchased are in the ground (570 as of 8/31) we have 4 of each size in stock for new installations, all new installation will be complete by mid-September

Responded to several power outage alarms due to monsoons

Weed abatement is on-going

Installed a battery back-up at Molly Way Boost Station

Meter reads went well this month, (14) re-reads, 2 incorrect

Monthly were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

