

I.C.R. W.U.A. Monthly Operator Notes  
November 2018

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our lines, found a contractor building a parking lot next to the fire station advised him of the transmission line and asked why he didn't request Blue Stake

Waiting on Forteline to fabricate the spools for the new well meters we will install them when the spools are complete

Some incorrect multipliers were identified on some of the commercial meters and were corrected

1 data log was requested and completed in TRR

Both generators were serviced in TRR

Valve exercised program was completed at the end of Nov.  
per BMP's

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

