

I.C.R. W.U.A. Monthly Operator Notes
February 2019

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our lines

Received part and Meters for the wells should have meters installed by the end of the month

Meter reads went well this month, all new equipment seems to be working as planned

(4) new meters were installed (3) TRR (1) ICR

Water table has come up 8 feet over the last couple months

Both generators were load banked this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

