

I.C.R. W.U.A. Monthly Operator Notes
March 2019

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our lines

Three of the five well meters have been installed the other two will be in this month

Two water leaks were found in ICR one at the end of Warpaint (repaired)
And the other on Magner Dr. the excavator is having trouble locating this leak

Received a work order to install a meter on Spotted Eagle in ICR and found that the lot
and the lot next to it have no lateral service from the main, we have scheduled to have
both lots hot taped and laterals ran to the lots

Two chlorine pumps were replaced at both ICR wells

(3) new meters were installed (3) TRR

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

