

I.C.R. W.U.A. Monthly Operator Notes
April 2019

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our lines

Three of the five well meters have been installed the other two will be in this month

Two water leaks were found in ICR one at the end of Warpaint (repaired)
And the other on Magner Dr. (repaired) also repaired a leak in TRR on Simmonds Peak

Services at the end of Spotted Eagle in ICR were completed and hooked up. Excavation
across the road to the main was hot tapped and new lateral were laid/ asphalt was
replaced

The valve in front of the Grey Bears building was excavated for possible leak no leak
was found. It appears to have been ground water

A coolant leak was discovered on the Molly Way generator Gen-Tech was called and the
leak was repaired

(3) New meters were installed (3) TRR

Emergency call out for a customer with no water in the Preserve, problem was on
customer side

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

