

I.C.R. W.U.A. Monthly Operator Notes  
May 2019

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our lines

Three of the five well meters have been installed the other two will be in this month

Two water leaks were found and repaired, one in ICR on Warbonnet, the main was installed on top of culverts and over the years wore a hole in it the other was in TRR at the end of Bruno Canyon

Generators were serviced and the belts on the Copper Morgan generator were replaced

ADEQ did an inspection on both systems no violations were received

(5) New meters were installed (5) TRR

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

