

I.C.R. W.U.A. Monthly Operator Notes  
Sept. 2019

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our lines

The annual valve exercise program is under way for the year, ICR is complete moving over to TRR

Hydrant leak detection is complete, 3 leaks identified and fixed

5 new meter installs were completed

Two power outages were responded to in Sept.

The road to the TRR well field was washed out due to a rainstorm, This need to be addressed

All buildings are set up and ready for the winter season

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

