

I.C.R. Water Co. Monthly Operator Notes  
March 2021

General maintenance and operations are ongoing

Molly Way/Sterling Ranch flushing is ongoing

The easement road was checked twice to insure no leaks or issues with our lines

ICR Well #2 is back online with a new pump and motor equipment was installed with one fewer stick of column pipe to attempt to be above the curve in the well

12 inch main line near the Copper Morgan boost station came apart causing a major leak, line was excavated and repaired the same day.

A level transducer failed at the Cooper Morgan boost station, causing pressure loss in the system, transducer was replaced

Responded to air in water complaints caused by the above mentioned failures

(8) new meter installs (2) ICR (6) TRR

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

