

I.C.R. Water Co. Monthly Operator Notes
September 2021

General maintenance and operations are ongoing

Molly Way/Sterling Ranch flushing and fire pump exercise is ongoing

The easement road was checked twice to insure no leaks or issues with our lines

(2) Emergency call outs

Yearly system wide valve exercise program will be completed this month

Yearly hydrant leak detection was completed (1) leaking hydrant was found

92 blue stake ticket were completed

Weed abatement is on-going

(13) New meter installs (5) TRR (8) ICR

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

