

I.C.R. Water Co. Monthly Operator Notes  
October 2021

General maintenance and operations are ongoing

Molly Way/Sterling Ranch flushing and fire pump exercise is ongoing

The easement road was checked twice to insure no leaks or issues with our lines

System wide Engineering review has started with Civil Tech Engineering

All buildings heaters were checked and buildings winterized

Yearly system wide valve exercise program is complete

Dead-end line flushing is ongoing

103 blue stake ticket were completed

Weed abatement is on-going

(7) New meter installs (3) TRR (4) ICR

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

