

I.C.R. Water Co. Monthly Operator Notes  
November 2021

General maintenance and operations are ongoing

Molly Way/Sterling Ranch flushing and fire pump exercise is ongoing

The easement road was checked twice to insure no leaks or issues with our lines

System wide Engineering review is on-going with Civil Tech Engineering we have been providing information that has been requested

Dead-end line flushing is ongoing

Emergency call out for leak on Electra Dr., leak was repaired

88 blue stake ticket were completed

(10) New meter installs (5) TRR (5) ICR

We are having some weird water loss reading in TRR, we suspect the lake line meter is going bad. Called the meter rep. waiting for him to come out and check calibration.

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

