

I.C.R. Water Co. Monthly Operator Notes
January 2022

General maintenance and operations are ongoing

Molly Way/Sterling Ranch flushing and fire pump exercise is ongoing

The easement road was checked twice to insure no leaks or issues with our lines

System wide Engineering review is on-going with Civil Tech Engineering we have been providing information that has been requested

57 blue stake ticket were completed

(10) New meter installs (7) TRR (3) ICR

It appears that the TRR lake meter has been going bad for several months. New meter has been ordered and will be replaced as soon as it arrives

We had an issues with the Hydro tank at Molly Way boost station, issue has been resolved

Emergency call out for low water pressure in TRR, the generator tech. was on-site for maintenance and tripped the VFD panel

We are working on rodent issues at the Cooper Morgan boost station generator

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

