

I.C.R. Water Co. Monthly Operator Notes
February 2022

General maintenance and operations are ongoing

Molly Way/Sterling Ranch flushing and fire pump exercise is ongoing

The easement road was checked twice to insure no leaks or issues with our lines

System wide Engineering review is on-going with Civil Tech Engineering we have been providing information that has been requested

76 blue stake ticket were completed

(6) New meter installs (2) TRR (4) ICR

New lake meter was received and installed

Leak on Double Adobe was discovered and repaired at the Courtesy Rest Rooms

We are working on rodent issues at the Cooper Morgan boost station generator

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

