

I.C.R. Water Co. Monthly Operator Notes
March 2022

General maintenance and operations are ongoing

Molly Way/Sterling Ranch flushing and fire pump exercise is ongoing

The easement road was checked twice to insure no leaks or issues with our lines

System wide Engineering review is on-going with Civil Tech Engineering we have been providing information that has been requested

62 blue stake ticket were completed

(10) New meter installs (8) TRR (2) ICR

New VFD installations on all wells are completed

Emergency call out at Cooper Morgan boost station

Lake line is on 8hrs. per day @430 gpm

Enviro Tech completed the Manager relay issue repair, new soft start at Molly Way boost station, repaired float issue at Cooper Morgan boost station.

Waiting on costs and availability of Cooper Morgan boost pump rebuild

Meter reads went good this month

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time

